Dykema Gossett PLLC
Capitol View
201 Townsend Street, Suite 900
Lansing, MI 48933
WWW.DYKEMA.COM
Tel: (517) 374-9100
Fax: (517) 374-9191

Richard J. Aaron
Direct Dial: (517) 374-9198
Direct Fax: (855) 230-2517
Email: RAaron@dykema.com

April 21, 2026

Lisa Felice
Executive Secretary
Michigan Public Service Commission
7109 West Saginaw Highway
3rd Floor
Lansing, MI 48917

Re: Case No. U-12270

Dear Ms. Felice:

Enclosed for electronic filing is Presque Isle Electric & Gas Co-op's MPSC Service Quality and Reliability Standards for Electric Utilities R460.731 Annual Report for 2025.

If you have any questions, please contact me.

Sincerely,

Dykema Gossett PLLC

Richard J. Aaron

Digitally signed by: Richard J. Aaron
DN: CN = Richard J. Aaron email = raaron@dykema.com C = AD O = Dykema OU = Dykema
Date: 2026.04.21 15:50:17 -04'00'

Richard J. Aaron

Enclosure

025819.000999 4850-8884-2679.2

MPSC Service Quality and Reliability Standards for Electric Utilities
R460.731 Annual Report

Utility or Cooperative:	Presque Isle Electric & Gas Co-op
Year:	2025

SUMMARY TABLE R460.732(s)

	Meter Reading Factor R460.732 (a)	New Service Installation Factor R460.732(b)	Wire Down Relief Factor R460.732 (c)		Outage Restoration				CEMI4	
					All Conditions R460.732 (d)	Normal Conditions R460.732 (e)	Gray-Sky Conditions R460.732 (f)	Catastrophic Conditions R460.732 (g)	Sustained Interruptions R460.732 (h)(i)	
	Meter Reading Factor (Percentage)	*New Services Installed in 15 Business Days or Less (Percentage)*	*The percentage of the first responder guarded downed wires that are relieved by an electric utility representative within 120 minutes after notification in MSAs.*	*The percentage of the first responder guarded downed wires that are relieved by an electric utility representative within 180 minutes after notification in non-MSAs.*	*Percentage of Customers Restored in 36 Hours or Less*	*Percentage of Customers Restored in 8 Hours or Less*	*Percentage of Customers Restored in 24 Hours or Less*	*Percentage of Customers Restored in 48 Hours or Less*	*Percentage of Customers Served Experiencing 4 or More Sustained Interruptions*	*Number of Customers Experiencing 4 or More Sustained Interruptions*
Utility or cooperative performance during year	95.5%	94.5%	**NA, no MSAs**	99.0%	96.1%	96.6%	82.3%	82.2%	36.3%	12,978
MPSC Annual Performance Standard	95% or more	90% or more completed within 15 business days	90% or more within 120 minutes in MSAs	90% or more within 180 minutes in non-MSAs	90% or more customers restored in 36 hours or less	90% or more customers restored in 8 hours or less	90% or more customers restored in 24 hours or less	90% or more customers restored in 48 hours or less	6% or less before 2030; 5% or less in 2030 or later	
Did utility or cooperative comply with performance standard (Yes/No)	Yes	Yes	NA	Yes	Yes	Yes	No	No	No	

A detailed explanation of the steps the electric utility or cooperative is taking to bring its performance to an acceptable level. If more than 6% of customers experienced 4 or more sustained interruptions within the year and that year was 2029 or a prior year, or if more than 5% of customers experienced 4 or more sustained interruptions within the year and that year was 2030 or a future year, a description of all catastrophic conditions experienced during the year is also required. (Can be put on a separate page.) R 460.732 (h)(ii) and R 460.732 (h)(iii).	R460.732 (f&g) On March 28th 2025 PIE&G's system was hit with a series of ice storms accumulating up to 2" of ice. The entire system was affected resulting in system wide outages lasting up to 3 weeks. We have developed work plans to target outages hot spots and harden them against ice and tree damage. The work plans for upcoming years include underground and shielded spacer wire technologies. R460.732 (h) Members that had 4 or more outages is higher than 6%. Response: The series of ice storms in March added at least one outage to most of the system and 2-3 outages to areas we attempted to restore early in the storm. Our strategic plan targets outage hotspots based on frequency and best impact for our community. We plan to use underground where feasible and shielded spacer wire technology where aerial is the best option. The work plans specifically targets areas where members experienced 4 or more outages per year.

CUSTOMER CREDITS PROVIDED DURING THE YEAR

Item	Sector	Number of credits provided	Total Customer Credits ($) (1)
Customer Credits Provided for Failure to Restore Service within 96 Hours of the Start of Sustained Interruption during Catastrophic Conditions R460.732(i)	*Residential* *Commercial* *Industrial*	Exempt Case # U-21414	
Customer Credits Provided for Failure to Restore Service within 48 Hours of the Start of Sustained Interruption during Gray Sky Conditions R460.732(j)	*Residential* *Commercial* *Industrial*	Exempt Case # U-21414	
Customer Credits Provided for Failure to Restore Service within 16 Hours of the Start of Sustained Interruption during Normal Conditions R460.732(k)	*Residential* *Commercial* *Industrial*	Exempt Case # U-21414	
Customer Credits Provided to Individual Customers Who Experienced 6 or more Sustained Interruptions. R460.732(l)	*Residential* *Commercial* *Industrial*	Exempt Case # U-21414	

WORST PERFORMING CIRCUITS DURING THE YEAR

1. For each electric utility with 1,000,000 or more customers, a list of its 10 worst performing circuits for the prior year in terms of SAIDI and SAIFI. For each listed circuit, provide the following information below. R460.732(m) and R 460.732 (o). Please see the definition of "circuit" below in (8).

2. For each electric utility or cooperative with less than 1,000,000 customers, a list of the worst performing 1% of circuits for the prior year in terms of SAIDI and SAIFI. For each listed circuit, provide the following information below. R460.732(n) and R 460.732 (o). Please see the definition of "circuit" below in (8).

Worst performing circuit(s) by SAIDI excluding major event days (MEDs) (7), (8), (11)

	Circuit 1	Circuit 2	Circuit 3	Circuit 4	Circuit 5	Circuit 6	Circuit 7	Circuit 8	Circuit 9	Circuit 10
Circuit Name	**BV2**									
Circuit Number	**2**									
Location of Circuit - zip codes (2)	48705, 48728 49747, 49753									
Circuit Length (miles)	**69**									
SAIDI excluding MEDs	1990.861									
SAIFI excluding MEDs	5.679									
SAIDI all conditions	31245.916									
SAIFI all conditions	4.879									
Number of Customers Served	140									
Substation Name	Beaver Lake									
Last Circuit Trim (year) (3)	2019									
List of Outages and Causes (can be put on a separate page) (4)	Trees									
Corrective action to improve performance (can be put on a separate page)	Evaluating converting more of this feeder to underground									

Worst performing circuit(s) by SAIFI excluding MEDs (7), (8), (11)

	Circuit 1	Circuit 2	Circuit 3	Circuit 4	Circuit 5	Circuit 6	Circuit 7	Circuit 8	Circuit 9	Circuit 10
Circuit Name	**BV2**									
Circuit Number	**2**									
Location of Circuit - zip codes (2)	48705, 48728 49747, 49753									
Circuit Length (miles)	**69**									
SAIFI excluding MEDs	1990.861									
SAIDI excluding MEDs	5.679									
SAIFI all conditions	31245.916									
SAIDI all conditions	4.879									
Number of Customers Served	140									
Substation Name	Beaver Lake									
Last Circuit Trim (year) (3)	2019									
List of Outages and Causes (can be put on a separate page) (4)	Trees									
Corrective action to improve performance (can be put on a separate page)	Evaluating converting more of this feeder to underground									

	CEMI0	CEMI1	CEMI2	CEMI3	CEMI4	CEMI5	CEMI6	CEMI7	CEMI8	CEMI9	CEMI10
CEMI Reporting for Indices CEMI0 through CEMI10+ R460.732(p) (5)	19.7%	80.4%	63.3%	48.9%	36.3%	26.1%	18.4%	12.2%	9.1%	7.7%	4.8%

CELID		
CELID Reporting R460.732(o) (6)	**CELID8hours**	94.1%
	CELID24hours	86.8%

R460.732(q) (6)	**CELID48hours**	79.8%

MOMENTARY INTERRUPTIONS	
Number of Non-Residential Customers Experiencing Momentary Interruptions R460.732(r)	Exempt Case # U-21509

System-wide SAIDI, SAIFI, and CAIDI (9)

	All conditions						**Excludes MEDs** (11)					
	SAIDI		**SAIFI**		**CAIDI**		**SAIDI**		**SAIFI**		**CAIDI**	
Year	Annual	5 year average	Annual	5 year average	Annual	5 year average	Annual	5 year average	Annual	5 year average	Annual	5 year average
2025	9074.44	1992.35	1.49	1.25	2403.72	632.27	306.66	205.52	1.42	1.19	205.84	173.27
2024	207.04	227.69	1.29	1.25	160.18	185.60	181.93	186.26	1.24	1.17	146.96	162.29
2023	230.17	238.42	0.99	1.23	233.36	196.93	194.48	187.27	0.93	1.13	209.27	168.47
2022	226.26	239.77	1.12	1.32	202.83	183.59	162.68	192.54	1.01	1.21	160.77	159.75
2021	223.83	246.70	1.39	1.38	161.28	180.07	181.86	204.17	1.27	1.28	143.52	160.73

Power Quality information (10)

Power quality information shall contain data on: **a) all power quality investigations conducted in the past year for industrial customers who have requested a power quality investigation as a result of an event originating from utility equipment; and** **b) power quality investigations conducted in the past year into any power quality event. For purposes of this form, a power quality event is defined as an event that affected customers on a single circuit or substation; resulted in damage to customer appliances, equipment, or wiring; and occurred within a 24-hour period. (Can be put on a separate page or pages.)**	

DEFINITIONS AND NOTES

(1) "Total customer credits" means the dollar amount of customer credits provided on customer bills during the year.

(2) "Location of Circuit - zip codes" refers to the zip codes where spans of the circuit are located.

(3) "Last circuit trim (year)" is the last year there was trimming on the circuit as part of a normal tree trim cycle (not reactive trimming)

(4) "List of outages and causes" - please discuss outages that meet the definition of a "major interruption" as defined by R 460.3102(j)

(5) For CEMI0 through CEMI10+ reporting, please provide percentages. Reporting should be all conditions.

(6) For CELID reporting, please provide percentages. Reporting should be all conditions and follow the definition of CELID Single Interruption Duration per IEEE 1366-2022 section 4.2.8. Do not double count multiple outages of that fall within the same time bracket. For example, a customer experiencing two nine-hour outages should only be reported once in CELID8hrs. Longer outages may qualify for inclusion in multiple CELID metrics. For example, a customer experiencing a 30-hour outage may be reported in CELID8hrs and CELID24hrs.

(7) For the worst performing circuits sections, SAIDI and SAIFI should be calculated on a system basis. Worst performing circuits operated by utilities and cooperatives with less 1,000,000 customers should not be compared to worst performing circuits that are operated by utilities with 1,000,000 or more customers.

(8) For the worst performing circuits sections, a circuit is defined as a substation feeder or line exit from a substation serving at least 10 metered customers.

(9) The system-wide SAIDI, SAIFI, and CAIDI data is requested pursuant to MCL 460.55 and the July 7, 2023 order in Case No. U-12270.

(10) Power quality information is being requested pursuant to the July 7, 2023 order in Case No. U-12270.

(11) Major event day, or MED, is defined according to IEEE 1366-2022.

* A customer shall be defined as a "metered electric service."

** Interruptions that occur as a result of outages on customer-owned facilities, or loss of supply from another utility, should not be included in IEEE reliability index calculations.