



January 20, 2026

Ms. Lisa Felice
Executive Secretary
Michigan Public Service Commission
7109 W. Saginaw Highway
Lansing, MI 48917

Dear Ms. Felice:

On June 19, 2000, the Michigan Public Service Commission, in Case No. U-12486, issued an Opinion and Order regarding mercury emissions from electrical generation facilities. The regulation is codified as Michigan Public Act 141 of 2000 Subsection 10d (9) and states the following:

"The public service commission shall take the necessary steps to ensure that all electrical power generating facilities in the state comply with all rules, regulations, and standards of the federal environmental protection agency regarding mercury emissions."

Wolverine Power Supply Cooperative, Inc. (Wolverine) owns and operates various electrical generating facilities in the State of Michigan. None of the electrical generating units operating at Wolverine's plants are coal-fired units; all units are fired with either natural gas and/or distillate oil.

The attached report covers the 2025 reporting season and provides a brief overview of the federal mercury regulations associated with electrical generating units and describes Wolverine's compliance with these federal mercury regulations.

Please contact me at 231.775.5700 if you have any questions or would like additional information. Thank you.

Sincerely,

A handwritten signature in blue ink, appearing to read "Joe A. Hazewinkel".

Joseph A. Hazewinkel
Director of Environmental Affairs

Cc: Joseph Baumann, Tom King

STATE OF MICHIGAN
BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter, on the Commission's own motion	)	
To require an annual report on compliance with	)	
The mercury emissions provisions of 2000 PA 141	)	Case No. U-12486

**Report on the Compliance Status of Each Electrical Power
Generating Facility in Michigan with all
Rules, Regulations and Standards of the
Federal Environmental Protection Agency
Regarding Mercury Emissions as required under
2000 PA 141**

Submitted by:

**Wolverine Power Supply Cooperative, Inc.
10125 West Watergate Road
Cadillac, MI 49601
Phone (231) 775-5700**

January 20, 2026

INTRODUCTION

Wolverine Power Supply Cooperative, Inc. (Wolverine) is submitting the enclosed report in response to the Michigan Public Service Commission June 19, 2000 order Case No. U-12496. The Commission ordered the owner or operator of each electrical power generating facility in Michigan to file a report showing it is in compliance with all applicable federal Environmental Protection Agency (EPA) regulations governing mercury emissions and how it determined it is in compliance. If any facility is not in compliance, the report shall detail how it will bring itself into compliance and shall commit to a date for full compliance.

The Commission also ordered that the first report required under Case No. U-12486 be filed within 90 days of the Commission's June 19, 2000 order and that each subsequent report be filed by January 31 of each succeeding year. The following report is intended to satisfy the requirements of Subsection 10d (9) 2000 PA 141; MCL 460.10d(9); and MSA 22.13 (10d)(9) for the January 31, 2026 reporting requirement.

**Report Outlining the Compliance Status with all Applicable
U.S. Environmental Protection Agency (EPA) Regulations
Governing Mercury Emissions**

Wolverine is the owner and operator of multiple natural gas and/or distillate oil fired power plants in the State of Michigan (**refer to Table 1**). Based upon a review of the most recent United States (U.S.) EPA databases, the combustion of natural gas and/or light distillate oils is not a significant source of mercury air emissions. The units which Wolverine owns and operates are not subject to the EGU MATs rule, 40 C.F.R. Part 63 subpart UUUUU and Wolverine has not identified any other existing U.S. EPA regulations governing mercury emissions from these units. Therefore, Wolverine has no reporting requirements relative to its compliance with any applicable federal mercury emission requirements.

Conclusions

In the State of Michigan, all power produced by Wolverine is generated by the use of natural gas and/or distillate oil fired combustion turbines and internal combustion engines. These combustion sources are inherently clean with regard to the emission of metallic compounds such as mercury. The U.S. EPA has long recognized that the emissions of mercury from such sources are extremely minor, and to date, do not warrant controls or regulation. Based on the information provided above, Wolverine hereby submits that the facilities listed in **Table 1** are in compliance with all federal EPA regulations governing mercury emissions as those regulations are not applicable to the identified units.

Dated: January 20, 2026

Wolverine Power Supply Cooperative, Inc.

A handwritten signature in blue ink, appearing to read 'Joe A. Hazewinkel', is written over a horizontal line.

Joseph A. Hazewinkel
Director of Environmental Affairs

Table 1: Wolverine Power Supply Cooperative, Inc.

Inventory of Electric Generating Units Located in the State of Michigan

Facility Name	Unit Number	Type of Unit	Type of Fuel Used
Burnips	Unit 8	Simple Cycle Combustion Turbine	Natural Gas
Gaylord	Unit 1	Simple Cycle Combustion Turbine	Natural Gas
	Unit 2	Simple Cycle Combustion Turbine	Natural Gas
	Unit 3	Simple Cycle Combustion Turbine	Natural Gas
Hersey	Unit 9	Simple Cycle Combustion Turbine	Natural Gas
	Unit 10	Simple Cycle Combustion Turbine	Natural Gas
	Unit 11	Internal Combustion Engine	Diesel
Sumpter	Unit 1	Simple Cycle Combustion Turbine	Natural Gas
	Unit 2	Simple Cycle Combustion Turbine	Natural Gas
	Unit 3	Simple Cycle Combustion Turbine	Natural Gas
	Unit 4	Simple Cycle Combustion Turbine	Natural Gas
Tower	Unit 4	Simple Cycle Combustion Turbine	Diesel
Vestaburg	Unit 8	Simple Cycle Combustion Turbine	Diesel / Natural Gas