



January 23, 2026

Executive Secretary
Michigan Public Service Commission
P.O. Box 30221
Lansing, MI 48909

RE: U-12486 Annual Mercury Report – Calendar Year 2025

To Whom it May Concern:

This report is submitted in response to the commission's June 19, 2000 order in the captioned docket for case number U-12486. Genesee Power Station (GPS) LP owns a 35 MW electrical power generating facility located in Flint, MI. The primary fuel for the facility is wood waste. The unit is not subject to the Mercury and Air Toxics Standard (MATS) under 40 CFR Part 63, Subpart UUUUU. The boiler unit at GPS is however subject to the Industrial Boiler Maximum Achievable Control Technology Standard (IBMACT) under 40 CFR Part 63, Subpart DDDDD which contains a mercury (Hg) emission limit requirement. This Hg emission requirement has been rolled into the facility renewable operating permit MI-ROP-N3570-2023. Testing for Hg is currently required by the IB MACT rule every 37 months for this facility. The last test conducted in May 2025 demonstrated compliance with the IB MACT Standard. Test results were submitted to Michigan EGLE and EPA within the required timeframe.

GPS is currently in compliance with the applicable mercury regulations.

Regards,

Kathryn M. Cunningham, P.E.
NorthStar Corporate Environmental Support

Cc: Thomas Clift, NorthStar
Brad Wargnier, NorthStar GPS

Genesee Power Station Limited Partnership
G-5310 NORTH DORT HIGHWAY
FLINT, MICHIGAN 48505
(810) 785-4144
(810) 785-2905 (FAX)